



Department of Labor & Industries – WISHA Services

Framing Emphasis Checklist - Safety

Employer _____

Report Number: _____

CSHO Name: _____

Date of inspection: _____

		YES	NO	N/A
PERSONAL PROTECTIVE EQUIPMENT (PPE)				
Individual hard hats available on site?	155-205(2)			
Hard hats used when exposed to flying or falling objects?	155-205(3)			
Eye protection worn?	155-215(1)(a) & 155-350 (3)			
Suitable clothing -short sleeved shirt and long pants worn?	155-200(6)			
Proper footwear worn?	155-212			
Is leg protection used during chainsaw usage?	155-211			
FALL PROTECTION				
Is fall protection used when exposed to 10' fall hazard?	155-24510			
Are fall protection anchorage points installed properly?	155-24510(2)(a)(ix)			
Is fall protection work plan available and implemented?	155-24505(1)			
LADDERS / STAIRWAYS				
Stairway installed before 2 nd floor studs raised?	155-477(1)(f)(i)			
Guardrail and handrail on stairways with 4 or more risers?	155-477(3)(a)(i)			
Ladders extend 3 ft beyond upper landing?	155-480(2)(a)			
Ladders used for purpose they were designed for?	155-480(2)(d)			
Top of ladder not being used as step?	155-480(2)(m)			
Defective ladder marked and removed from service?	155-480(2)(p)			
Ladder/stairway safety training program implemented?	155-48060 (1) (a)			
SAW GUARDING				
Hand-held power circular saws properly guarded?	155-370(2)			
Table saws properly guarded?	155-370(3)(a)			
Radial saws properly guarded?	155-370(4)(a)			
Power miter saws properly guarded?	155-370(7)			
STRUCTURE CONSTRUCTION				
Walls braced to prevent collapse?	155-035(8)			
Scaffolds fully planked and guarded?	155-483(2)(a) & (7)(a)			
Floor openings guarded (12" or more)?	155-505(4)(a)			
Wall openings guarded by standard railing or equivalent?	155-505(5)(a)			
Open sided surfaces guarded by standard railing or equivalent?	155-505(6)(a)			
Stair or ramp provided for break in elevation >19" ?	155-476(1)			
Ramp used for access is at least 18" wide?	155-515(1)			
ELECTRICAL				
Extension cords with ground pin?	155-447(6)(f)			
Extension cords free of improper splices?	155-449(7)(b)(iii)			
Multi-outlet J-Box are waterproof?	155-449(1)(a)(iii)			
GFCI or assured grounding program?	155-447 (2) (a) (i)			

CONTRACTOR REGISTRATION		YES	NO	N/A
Did employer have valid contractor's Registration?	Lic #: _____			
RELATED PROGRAM REQUIREMENTS				
Is the APP tailored to the business and hazards involved?	155-110 (2)			
Does the employer provide safety orientations?	155-110 (3)			
Is the APP outlined in written format?	155-110 (4)			
Is a Crew Leader-Crew Safety meeting held at beginning of job & weekly thereafter?	155-110(5) (a)			
Are safety meetings tailored to the operations?	155-110 (5) (b)			
Are safety meetings documented?	155-110 (6) (d) & (e)			
Are safety walk-around inspections conducted at the beginning of the job and weekly thereafter?	155-110 (9) (a)			
Are walk-around inspections documented and available for inspection?	155-110 (9) (b)			
Do employees work with hazardous chemicals/materials?				
Is there a hazard communication program that is written and implemented?	296-800-17005			
Is there an Chemical Inventory for chemicals on-site?	296-800-17010			
Is there an MSDS for each hazardous product?	296-800-17015			
Are employees provided HAZCOM training?	296-800-17030			
FIRST-AID				
Are first-aid supplies available on-site?	155-125(1)			
Is there a first-aid trained person or persons on site?	155-120(2)			
Are crew leaders and supervisors first aid trained?	155-120(3)			
HOUSEKEEPING				
Is proper housekeeping maintained at the jobsite?	155-020 (1) through (12)			
SANITATION				
*Adequate supply of potable water provided?	155-140(1)(a)			
*Toilets provided and maintained at jobsite?	155-140(4)(b) & 155-140(4)(d)			
MINORS				
Are any employees age 17 or younger?				
Is minor operating any power driven equipment, e.g. saws, nail guns, staplers?	296-125-030(5)(8)(13)			
Is minor roofing or working more than 10 feet off the ground?	296-125-030(15)(28)			
Does employer have a Minor Work Permit?	296-125-0200			

* Does not apply to mobile crews or normally unattended work locations per WAC 296-155-140 (1) (g) & (h) . Mobile crew is defined as "A work crew that routinely moves to a different work location periodically. Normally a mobile crew is not at the same location all day."

For employers who employ independent contractors, the independent contractors may be considered employees if the essence of the contract is his or her personal labor. More information can be found in RCW 49.17.020 (5).

ⁱ This emphasis checklist outlines fundamental requirements and is not inclusive of all safety and health requirements for employers in the construction industry. Other requirements can be found in the Washington Administrative Code (WAC) Chapters 296-24, 296-62 and 296-155. Information relevant to these requirements or further assistance can be found on the agency website located at: WWW.LNI.WA.GOV/WISHA

While some requirements are italicized due to their relevance to the framing emphasis, many of the hazards outlined here are known to cause serious injuries and can be cited when enforcement staff discover employee exposures to those hazards